





Test Summary of Individual Certificates

from the

Research & Development Center

Series: Kolorines JCP Byzantine

Date: 08/07/07

Size(s): 3/4 x 3/4 **Plant:** Sourced (999)

								Chemical	Stain		
		Production	Abrasion Resistance	Breaking Strength	SC	OF	Moh's	Resistance	Resistance	Water Abs.	LRV
		Date	ASTM C1027-99 & ISO 10545-7	ASTM C 648-04	ASTM C 1028-06		EN 101	ASTM C 650-04	ASTM C 1378-04	ASTM C 373-88	ASTM C 609-07
I	Color#	(Julian)	(Class)	(lbf)	Dry	Wet	(1-10)	(Pass/Fail)	(Pass/Fail)	(%)	%
Ī	Red	N/A	N/A	N/A	1.05	0.69	5	N/A	N/A	N/A	N/A

James Neel

Testing Manager

^{**} The information presented above represents testing results made in accordance with the most current, industry-recognized standard testing procedures and are offered in good faith as being accurate and typical of normal production to the best of our knowledge. Due to natural variation of raw materials and manufacturing processes, buyer may experience some variation between these test results and the product quality actually purchased and/or otherwise installed. Buyer should evaluate suitability and safety of product for buyer's' use since the conditions of use and maintenance are beyond our control. However, no guarantee or warranty of any kind, expressed or implied, is made with respect to the information contained herein.







Test Certificate

from the

Research & Development Center

Water Absorption

PRODUCT: Dal-Tile

DATE: 08/30/07

SERIES: Kolorines/Byzantine

GLAZE FINISH: Unglazed

COLOR NAME: 1-orange,2-Purple,3-Gree

SURFACE TEXTURE: Smooth, Gloss

SKU: N/A

ANSI TILE TYPE: Glass Tile

SOURCE: Sansy Tramel

NOTE: N/A

PLANT: Sourced (999)

PRODUCTION DATE: N/A

PROCEDURE:

ASTM C373-88

DESCRIPTION:

The sample(s) were placed in an oven at 150 degree centigrade for 1 hour, cooled and placed in a pot with distilled water. The sample(s) was then boiled for 5 hours and then retained in the water for 24 hours. The percent water absorption was calculated by the weight differential.

RESULTS:

Tile#	Water Absorption (%)				
1	0.00				
2	0.00				
3	0.00				

Average **0.00**

REQUIREMENTS:

ANSI A137.1 - 1988. The tile in the sample shall have a water absorption

not exceeding 0.5%

James Neel

Testing Manager

^{**} The information presented above represents testing results made in accordance with the most current, industry-recognized standard testing procedures and are offered in good faith as being accurate and typical of normal production to the best of our knowledge. Due to natural variation of raw materials and manufacturing processes, buyer may experience some variation between these test results and the product quality actually purchased and/or otherwise installed. Buyer should evaluate suitability and safety of product for buyer's' use since the conditions of use and maintenance are beyond our control. However, no guarantee or warranty of any kind, expressed or implied, is made with respect to the information contained herein.







Test Certificate

from the

Research & Development Center

BREAKING STRENGTH

PRODUCT: Dal-Tile **DATE:** 08/30/07

SERIES: Kolorines/Byzantine GLAZE FINISH: Unglazed

COLOR NAME: 1-orange,2-Purple,3-Green SURFACE TEXTURE: Select

SKU: N/A ANSI TILE TYPE: Glass Tile

SOURCE: Sansy Tramel **NOTE:** N/A

PLANT: Sourced (999) PRODUCTION DATE: N/A

PROCEDURE: ASTM C648-04

<u>DESCRIPTION:</u> The tile sample(s) is placed on a test fixture having 3 supports located in a circle.

The load is applied at the center, as per specification, until the sample(s) breaks.

MACHINE TYPE: Gabbrielli CRAB 2

FIXTURE TYPE: Steel rod equilateral triangle having sides of 1.50 inches.

REQUIREMENTS: ANSI standards require the breaking strength for this tile type to be greater than or equal to

250 pounds.

Number of Tile Tested: 3

RESULTS for this Sample:

Average: 545.0 Pass

All units are in lbf

James Neel